

**97.06 SPECIAL FACILITIES.** If the District Superintendent permits the pretreatment or equalization of waste flows, the design and installation of the plants and equipment shall be subject to the review and approval of the District Superintendent and subject to the requirements of all applicable codes, ordinances, and laws. Where preliminary treatment or flow-equalizing facilities are provided for any waters or wastes, they shall be maintained continuously in satisfactory and effective operation by the owner at the owner's expense.

**97.07 CONTROL MANHOLES.** When required by the District Superintendent, the owner of any property serviced by a building sewer carrying industrial wastes shall install a suitable control manhole together with such necessary meters and other appurtenances in the building sewer to facilitate observation, sampling, and measurement of the wastes. Such manhole, when required, shall be accessibly and safely located, and shall be constructed in accordance with plans approved by the District Superintendent. The manhole shall be installed by the owner at the owner's expense, and shall be maintained by the owner so as to be safe and accessible at all times.

**97.08 TESTING OF WASTES.** All measurements, tests, and analyses of the characteristics of waters and wastes to which reference is made in this chapter shall be determined in accordance with the latest edition of "Standard Methods of the Examination of Water and Wastewater," published by the American Public Health Association, and shall be determined at the control manhole provided, or upon suitable samples taken at said control manhole. In the event that no special manhole has been required, the control manhole shall be considered to be the nearest downstream manhole in the public sewer to the point at which the building sewer is connected. Sampling shall be carried out by customarily accepted methods to reflect the effect of constituents upon the sewage works and to determine the existence of hazards to life, limb, and property. (The particular analyses involved will determine whether a twenty-four (24) hour composite of all outfalls of a premise is appropriate or whether a grab sample or samples should be taken. Normally, but not always, B.O.D. and suspended solids analyses are obtained from twenty-four (24) hour composites of all outfalls whereas pH's are determined from periodic grab samples).

## CHAPTER 98

# ON-SITE WASTEWATER SYSTEMS

98.01 When Prohibited  
98.02 When Required  
98.03 Compliance with Regulations  
98.04 Permit Required  
98.05 Discharge Restrictions

98.06 Maintenance of System  
98.07 Systems Abandoned  
98.08 Disposal of Septage  
98.09 Minimum Lot Area

**98.01 WHEN PROHIBITED.** Except as otherwise provided in this chapter, it is unlawful to construct or maintain any on-site wastewater treatment and disposal system or other facility intended or used for the disposal of sewage.

*(Code of Iowa, Sec. 364.12[3f])*

**98.02 WHEN REQUIRED.** When a public sanitary sewer is not available under the provisions of Section 95.05, every building wherein persons reside, congregate or are employed shall be provided with an approved on-site wastewater treatment and disposal system complying with the provisions of this chapter.

*(IAC, 567-69.1[3])*

**98.03 COMPLIANCE WITH REGULATIONS.** The type, capacity, location, and layout of a private on-site wastewater treatment and disposal system shall comply with the specifications and requirements set forth by the Iowa Administrative Code 567, Chapter 69, and with such additional requirements as are prescribed by the regulations of the County Board of Health.

*(IAC, 567-69.1[3 & 4])*

**98.04 PERMIT REQUIRED.** No person shall install or alter an on-site wastewater treatment and disposal system without first obtaining a permit from the County Board of Health.

**98.05 DISCHARGE RESTRICTIONS.** It is unlawful to discharge any wastewater from an on-site wastewater treatment and disposal system (except under an NPDES permit) to any ditch, stream, pond, lake, natural or artificial waterway, drain tile or to the surface of the ground.

*(IAC, 567-69.1[3])*

**98.06 MAINTENANCE OF SYSTEM.** The owner of an on-site wastewater treatment and disposal system shall operate and maintain the system in a sanitary manner at all times and at no expense to the City.

**98.07 SYSTEMS ABANDONED.** At such time as a public sewer becomes available to a property served by an on-site wastewater treatment and disposal system, as provided in Section 95.05, a direct connection shall be made to the public sewer in compliance with these Sanitary Sewer chapters and the on-site wastewater treatment and disposal system shall be abandoned and filled with suitable material.

*(Code of Iowa, Sec. 364.12[3f])*

**98.08 DISPOSAL OF SEPTAGE.** No person shall dispose of septage from an on-site treatment system at any location except an approved disposal site.

**98.09 MINIMUM LOT AREA.** No permit shall be issued for any on-site wastewater treatment and disposal system employing sub-surface soil absorption facilities where the area of the lot is less than fifteen hundred (1,500) square feet.